

**ADDENDUM 3  
TO  
CITY OF BELLE ISLE  
REQUEST FOR PROPOSALS  
Sidewalk Repair and Replacement  
RFP# 23-03**

This Addendum is issued on March 10, 2023. The issuance of this addendum does not change the submission dates.

1. What is the thickness for industrial driveways?

**8-inches, or 6-inches with welded wire mesh.**

2. Can fiber be used in lieu of the welded wire mesh for the commercial driveways?

**Commercial driveways will not require either fiber or welded wire mesh. However, industrial driveways will require welded wire mesh.**

3. Is the one pint of lampblack paint on the concrete mix also deleted?

**Yes.**

4. Item #4 Minor Concrete Repair (reinforced Storm Drain Curb inlet lid). Can we please have some clarification on what is the intent for this scope? Is this for the demolition and reconstruction of inlet tops? A picture or explanation would suffice.

**This item has been removed.**

5. Specification on the catch basin inlet tops that are to be used when repairing.

**This item has been removed.**

6. Will the base requirement be just for new construction or for all replacement of sidewalk, curb & gutter, driveways, etc.

**The base requirement shall apply to all new construction works. Replacement areas shall be checked for existing base compaction prior to formwork. However, should the existing base be sufficient, then it does not need to be fully removed and replaced.**